



May 24, 2016

American Promise Group  
4366 Military  
Detroit, MI 48210

**RE: Jalen Rose Leadership Academy  
15000 Trojan  
Detroit, MI 48235  
Date: April 27, 2016  
AEC Project Number: 1515-16001**

Dear Mr. Kochis,

American Environmental Consultants (AEC), LLC conducted lead in water sampling at Jalen Rose Leadership Academy, located at 15000 Trojan in Detroit, Michigan. The sampling was conducted in response to a memorandum put forth by the Detroit Health Department. The sampling was conducted on April 27, 2016, by AEC representative, Jef Fox.

#### **Observations**

AEC observed the areas to be sampled and no obvious lead components were observed in the portions of the water system viewed. AEC attempted to collect samples from randomly targeted locations including but not limited to water main, kitchen faucets, drinking fountains, bathroom faucets, slop sinks and classroom faucets. All samples were collected as a first draw following a rest period of a minimum of 6 hours.

#### **Methodology**

The samples were collected utilizing the protocols described in the EPA lead and copper testing guidelines and the 3 T's for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance. The samples were submitted to National Testing Laboratories, Ltd., located at 556 South Mansfield, in Ypsilanti, MI 48197-5166. The phone number to National Testing Laboratories is (440) 449-2525. The samples were analyzed by the EPA Method 200.8. A standard turnaround time was indicated on the chain of custody. A 250 milliliter sample was collected at each point.

---

## Results

The following table summarizes the results from the sampling. The certificates of analysis and chain of custody are attached for further reference.

Number	ID Code	Description	Result	EPA Action Level
1	187210	Kitchen Hand Sink CW	0.006 mg/L	0.015 mg/L
2	187209	Main Hall DW Fountain	ND	0.015 mg/L
3	187208	2 <sup>nd</sup> Floor DW Fountain	ND	0.015 mg/L
4	187207	2 <sup>nd</sup> Floor Women's RR	0.002 mg/L	0.015 mg/L
5	187206	BR Slop Sink CW	0.008 mg/L	0.015 mg/L

All samples were below the EPA Action Level.

## Conclusion

The samples were below the EPA Action Level and no further action is necessary.

## Limitations

The information and opinions obtained in this report are for the exclusive use of AEC's Client. No distribution to or reliance by other parties may occur without the express written permission of AEC. AEC will not distribute this report without your written consent or as required by law or Court order. The information and opinions that are contained in this report are given in light of that assignment. The report must be reviewed and relied upon only in conjunction with the terms and conditions expressly agreed upon by the parties and as limited therein. Any third parties who have been extended the right to rely on the contents of this report by AEC (which is expressly required prior to any third party release), expressly agrees to be bound by the original terms and conditions entered into by AEC and Client.

Subject to the above terms and conditions, AEC accepts responsibility for the competent performance of its duties in executing the assignment and preparing reports in accordance with the normal standards of the profession, but disclaims any responsibility for consequential damages. Although AEC believes that the results contained herein are reliable, AEC cannot warrant or guarantee that the information provided is exhaustive or that the information provided by Client or third parties is complete or accurate.

AEC appreciates the opportunity to be of service to your organization and looks forward to working with you on future projects. If you have any questions regarding this report please feel free to contact us at our office at 313-491-2600.

Sincerely,

**American Environmental Consultants, LLC**

A handwritten signature in black ink, appearing to read 'Jef Fox', with a stylized flourish at the end.

Jef Fox  
Project Manager

**National Testing Laboratories, Ltd**  
 556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 353996**

**5/4/2016**

**Customer:** American Environmental Consultants  
 Jeff Fox  
 12838 Gavel Street  
 Detroit, MI 48227

**Source:** 187210  
**Source City:** Detroit  
**Source State:** MI

**Date/Time Received:** 4/28/2016 16:35

**Collected by:** J. Fox

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.015	mg/L	0.001	0.006	1	4/27/2016 06:10		5/2/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 353997**

**5/4/2016**

**Customer:** American Environmental Consultants  
 Jeff Fox  
 12838 Gavel Street  
 Detroit, MI 48227

**Source:** 187209  
**Source City:** Detroit  
**Source State:** MI

**Date/Time Received:** 4/28/2016 16:35

**Collected by:** J. Fox

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.015	mg/L	0.001	ND	1	4/27/2016 06:11		5/2/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**  
 556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 353998**

**5/4/2016**

**Customer:** American Environmental Consultants  
 Jeff Fox  
 12838 Gavel Street  
 Detroit, MI 48227

**Source:** 187208  
**Source City:** Detroit  
**Source State:** MI

**Date/Time Received:** 4/28/2016 16:35

**Collected by:** J. Fox

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.015	mg/L	0.001	ND	1	4/27/2016 06:12		5/2/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**  
 556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 353999**

**5/4/2016**

**Customer:** American Environmental Consultants  
 Jeff Fox  
 12838 Gavel Street  
 Detroit, MI 48227

**Source:** 187207  
**Source City:** Detroit  
**Source State:** MI

**Date/Time Received:** 4/28/2016 16:35

**Collected by:** J. Fox

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.015	mg/L	0.001	0.002	1	4/27/2016 06:14		5/2/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*